

PJ

### HYGENIC AND SANITARY CERTIFICATE

No-Dy. CS(H) 2018/825.


Date:- 29-10-18.

It is certified that....*Rishikul Vidyapeeth*.....  
*Peeth, Devru Road, Sonpat*.....  
*(Haryana)*.....was inspected  
by...*Dy. Civil Surgeon & Health Inspector*.....


Safe drinking water, hygienic & sanitary/conditions were found satisfactory.

Previous Number.....

The above valid for one year *oct-2019*.



**PRINCIPAL  
RISHIKUL VIDYAPEETH  
SONEPAT**

*[Signature]*  
Civil Surgeon,  
Sonapat.  


**PUBLIC HEALTH ENGINEERING DEPARTMENT WATER TESTING LABORATORY, SONIPAT**

Lab. No: 136PC/2020

1. **Sender's Address** : Rishikul Vidyapeeth School, Sonipat  
 2. **Source of Sample** : T/W  
 3. **Collected on** : 23.06.2020  
 4. **Received on** : 23.06.2020  
 5. **Ref. No.** : ---  
 6. **Sample Submitted by** : Sh.Virender Singh

Memo No: 220

Dated : 26/6/2020

**Chemical Analysis Report**

Sr. No.	Substance/Characteristic	Result	Desirable Limit	Maximum Permissible Limit (In Absence of Alternate Source)
			As per IS:10500-2012 (second Revision)	
1	Total Dissolved Solids, mg/l	892	500	2000
2	Total Hardness, mg/l	390	200	600
3	Calcium (as Ca), mg/l	108	75	200
4	Magnesium (as Mg), mg/l	28.8	30	100
5	Alkalinity, mg/l	300	200	600
6	Chloride (as Cl), mg/l	156.2	250	1000
7	Sulphate (as SO <sub>4</sub> ), mg/l	78	200	400
8	Fluoride (as F), mg/l	0.68	1.0	1.5
9	Iron (as Fe), mg/l	0.02	1.0	No relaxn.
10	Nitrate (as NO <sub>3</sub> ), mg/l	1.4	45	No relaxn.
11	pH value	7.99	6.5-8.5	No relaxn.

\* Reliability of sample lies with the collector/sender. The Sample was not collected by this lab.

**OPINION**

The above mentioned analysis of water sample meet the requirement of IS: 10500-2012 (Second Revision)

*(Signature)*  
**PRINCIPAL**  
**RISHIKUL VIDYAPEETH**

*(Signature)*  
 Chemist,  
 Public Health Engineering Deptt.  
**CHEMIST**  
 Water Testing Laboratory, Sonipat